



Approved (SPF) Spray Foam Manufacturer and Type	Wet Film	Dry Film	Coverage Rate Per Gallon	IFTI ICC-ESR Evaluation report	IFTI IAPMO Evaluation report	SPF Manufacturer Evaluation Report
Foam Direct Polytite 1.7	18	12	89 sq ft	Update in Progress	Update in Progress	<a href="#">CCRR-0361</a>
Foam Direct Polytite 2.0	18	12	89 sq ft	Update in Progress	Update in Progress	<a href="#">CCRR-0361</a>
Foam Direct Polytite 2.0 High Lift	18	12	89 sq ft	Update in Progress	Update in Progress	<a href="#">CCRR-0361</a>

**Approved Foam Testing Matrix For DC315**

**Building Code Fire Performance Requirements for SPF:** The International Building Code (IBC) mandates that SPF be separated from the interior of the building by a prescriptive 15-minute thermal barrier, or other approved covering. **DC315 Carries IAPMO ER-0499 and ICC-ESR 3702 Evaluation Report** confirming DC315 provides an alternative thermal barrier assembly to the prescriptive thermal barrier requirements and all testing complies with the 2012 IBC Section 803.1.2 & 2603.10. 2012 IRC Section 316.6. 2015 IBC Section 803.2.1, 803.11, 2603.9 and 2015 IRC Section 316.6. DC 315 has also been tested as an ignition barrier under AC 377 Appendix X and meets the requirements of ICC-ES AC377 and AC456 Criteria.

**Light Gold Cells are Ignition Barrier**    **Light Green Cells are Thermal Barrier**



Visit our Web site [www.painttoprotect.com](http://www.painttoprotect.com)

[Application Guide](#)   [Ventilation Guide](#)   [Job Work Report](#)   [Job Site Label](#)   [Safety Data Sheets](#)   [Master Specification](#)   [Recommended Sprayer](#)